

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1591:193 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Model EST3 remote annunciator. The unit is modular in construction. The various options for the EST3 remote annunciator is as followed:

3-ANNCPU, 3-ANNCPU1	CPU Module for Remote Annunciator
3-ANNSM	Driver
3-ANNBF	Blank Filler Module
3-LCD	LCD Display Module
3-RCLM, 3-6ANN, 3-10ANN	Enclosure
3-24R, 3-24Y, 3-24G	LED Display
3-12SG, 3-12SR, 3-12SY	LED Display
3-12/S1GY, 3-12/S1RY	LED Display
3-12/S2Y	LED Display
3-6/3SIG2Y, 3-6/3SIGYR	LED Display
3-6ANN/D, 3-10ANN/D	Enclosure Door
3-RLCM/D	Enclosure Door
3-RLCM/B, 3-6ANN/B	Enclosure
3-RLCM/B-S, 3-6ANN/B-S	
3-10ANN/B-S, 3-LCDANN	
3-10ANN/B	

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as remote annunciator for use with listee's separately listed compatible fire alarm control units.

NOTE: Formerly 7120-1388:218

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager